




# SUPERIOR INTERLOCK CORPORATION

73-39 CENTRAL AVENUE  
GLENDALE, NY 11385  
(718) 821-8949 fax (718) 417-6162  
www.superiorinterlock.com



## INTERLOCK DATA SHEET FOR SUPERIOR-CORY KEY INTERLOCKS

date: 10 / 05 /2000

cust#: A - 123	ship to: XYZ SWITCHES	ultimate user #: 2862
cust: ABC ELECTRIC	987 MAIN STREET	name: CON ED OF NEW YORK
address: 125 SOME STREET	ANYTOWN	location: WATERSIDE GEN STATION
city: ANYTOWN state: NY		city: NEW YORK
zip: 12345 country: USA		state: NY
purchasing: JOE BUYER	state: NY	country: USA
P.O.#: 123456789LOCK	zip: 98765 country USA	
tel: 888-555-1234	marks: CAP BANK PROJECT	
fax: 888-555-5678	JOB # 6789	

ITEM	QTY	CATALOG NO.	TYPE NO.	BOLT EXT	E/W	INTER	KEY#	COVER	ACC	MH	O.H.	COIL VOLTAGE	REMARKS:
1	1	S105816Y	B-4003-1C	----	E	A1		N	NBR REV	MB4	N		TURN CAP BANK BKR OFF
2	1	S105810Y	B-4003-1	2	E	A1		DC2		MB4	Y		UNLOCK & OPEN AIR DISCONNECT SWITCH
3	1	S105810Y	B-4003-1	2	E	A2		N		MB4	N		CLOSE GROUND SWITCH AND REMOVE KEY
4	1	S105814Y	B-5003-2	----	E	A2		DC2		MB5	N		OPEN FIRST DOOR REMOVE "A3" KEY
					W	A3		DC2					
5	1	S105814Y	B-5003-2	----	E	A3		DC2		MB5	N		OPEN FIRST DOOR REMOVE "A4" KEY
					W	A4		DC2					
6	1	S105813Y	B-5003-1	----	E	A4		DC2		MB5	N		OPEN LAST DOOR

NOTE: BOLT EXTENSION TO BE SPECIFIED IN THE LOCKING BOLT WITHDRAWN POSITION. TRAVEL IS MECHANICALLY FIXED AT 3/4"  
O.H. = OPPOSITE HAND = LOCKING BOLT POINTS TO RIGHT. COVER Y/N YES SPEC DC1 OR DC2 N= NO COVER ACC=ACCESSORIES. MH=MOUNTING HARDWARE  
SOLENOID KEY RELEASE UNITS PLEASE SPECIFY REQUIRED "COIL VOLTAGE" SOL1=120vac SOL2=24vdc SOL3=125vdc SOL4=48vdc SOL5=240 Vac SOL6=250vdc

SPECIAL NOTES: PLEASE STAMP KEY INTERCHANGE ON ALL KEYS AND CYLINDERS